

# Overview on use of a Molten Salt HTF in a Trough Solar Field

D. Kearney      **Kearney & Associates**  
B. Kelly        **Nexant, Inc.**  
R. Cable,      **KJC Operating Co.**  
N. Potrovitza

U. Herrmann, P. Nava      **Flabeg Solar International**  
R. Mahoney, J. Pacheco    **Sandia Natl Labs Lab**  
D. Blake, H. Price        **NREL**

NREL Parabolic Trough Thermal Energy Storage Workshop  
Golden, CO, February 20-21, 2003

## **Disclaimer and Government License**

This work has been authored by Midwest Research Institute (MRI) under Contract No. DE-AC36-99GO10337 with the U.S. Department of Energy (the “DOE”). The United States Government (the “Government”) retains and the publisher, by accepting the work for publication, acknowledges that the Government retains a non-exclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for Government purposes.

Neither MRI, the DOE, the Government, nor any other agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe any privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not constitute or imply its endorsement, recommendation, or favoring by the Government or any agency thereof. The views and opinions of the authors and/or presenters expressed herein do not necessarily state or reflect those of MRI, the DOE, the Government, or any agency thereof.

# Concept & Objectives

**Utilize a molten salt as the heat transfer fluid in a parabolic trough solar field to improve system performance and to reduce the Levelized Electricity Cost (LEC)**



# Potential Advantages

- Can raise solar field output temperature to 450-500°C
  - **Rankine cycle efficiency increases to  $\geq 40\%$  range**
  - **$\Delta T$  for storage up to 2.5x greater**
- Salt is less expensive and more environmentally benign than present HTF
- Thermal storage cost drops 65% to  $< \$20/\text{kWh}$  compared to VP-1 HTF plant (no oil-to-salt HX)
- Solar Two experience with salts pertinent and valuable (piping, valves, pumps)

# Potential Disadvantages

- High freezing point of candidate salts
  - **Leads to significant O&M challenges**
  - **Innovative freeze protection concepts required**
- More expensive materials required in HTF system due to higher possible HTF temperatures
- Selective surface durability and salt selection will determine temperature limits
- Solar field heat losses will rise, though emissivity of 0.075 (from 0.1) would regain performance

# Some Key Questions

- What is the practical upper temperature limit?
- Is the O&M with salt feasible in a trough field, particularly freeze protection?
- Do materials, O&M, performance, etc. push the solar system capital cost too high, or in fact will the cost be reduced?
- Can we lower electricity cost with this approach? And add important flexibility with thermal storage?

# General System Conditions

Power block type:	Steam Rankine cycle	
Power block capacity:	50 MW gross	
Steam turbine inlet conditions:		
Pressure	66 bar, 100 bar	
Temperature	nominally 400-500C	
Steam turbine cycle efficiency: determined by GateCycle calculation, nominally 38.5-41.1% for these conditions.		
Solar field outlet salt temperature:	Nominal	450°C
	Maximum	~500°C
Optical:	Overall optical efficiency	0.75
Power Block	Capacity, MW	55 gross
Performance runs:	Thermal storage capacity	6h
	Annual Insolation	Barstow
Collector type	Generic SEGS type with advanced features	
Receiver	Current Solel Receiver	$\varepsilon=0.1@400C$
Operating scenario	Solar only	

# Characteristics of the Nitrate Salts and Therminol VP-1

Property	Solar Salt	Hitec	Hitec XL (Calcium Nitrate Salt)	LiNO <sub>3</sub> mixture	Therminol VP-1 Diphenyl biphenyl oxide
<b>Composition, %</b>					
<b>NaNO<sub>3</sub></b>	<b>60</b>	<b>7</b>	<b>7</b>		
<b>KNO<sub>3</sub></b>	<b>40</b>	<b>53</b>	<b>45</b>		
<b>NaNO<sub>2</sub></b>		<b>40</b>			
<b>Ca(NO<sub>3</sub>)<sub>2</sub></b>			<b>48</b>		
<b>Freezing Point, C</b>	<b>220</b>	<b>142</b>	<b>120</b>	<b>120</b>	<b>13</b>
<b>Upper Temperature, C</b>	<b>600</b>	<b>535</b>	<b>500</b>	<b>550</b>	<b>400</b>
<b>Density @ 300C, kg/m<sup>3</sup></b>	<b>1899</b>	<b>1640</b>	<b>1992</b>		<b>815</b>
<b>Viscosity @ 300C, cp</b>	<b>3.26</b>	<b>3.16</b>	<b>6.37</b>		<b>0.2</b>
<b>Heat capacity @ 300C, J/kg-K</b>	<b>1495</b>	<b>1560</b>	<b>1447</b>		<b>2319</b>

# Effective Storage Fluid Cost

<b>Salt</b>	<b>Temperature Rise</b>	<b>Cost per Kg</b>	<b>Storage Cost</b>
	°C	\$/kg	\$/kWh
Hitec (a) [142°C]	200	0.93	10.7
Solar Salt (b) [220°C]	200	0.49	5.8
Calcium Nitrate	200	1.19	15.2
[HitecXL] (c) [120°C]	150	1.19	20.1
	100	1.19	30.0
Therminol VP-1 (d)	100	3.96	57.5


a) 7:53 Na:K Nitrate, 40 Na Nitrite  
 b) 60:40 Na:K Nitrate

c) 42:15:43 Ca:Na:K Nitrate  
 d) Diphenyl/biphenyl oxide

# Candidate Thermal Storage Systems

- 2-Tank Configuration
  - Hot and Cold Tanks
  - Used at Solar Two ... good engineering experience
  - Judged to ready for commercial use
- Single Tank Thermocline
  - Good option -> costs estimated to be 65% less
  - Requires further development
  - 20 MWth prototype operated at SNLA
- Freeze protection in storage systems less complex than in field piping
- With VP-1, an expensive oil-to-salt HX is required. A molten salt HTF eliminates that need.


# HTF System Layout



# Comparative Levelized Electricity Cost

Engineering on solar field piping layout and design of major equipment was carried out for use in the performance and cost models

# Solar Field Layout



## Solar Field Parameters for 55 MWe Plant

125.0	Solar field peak thermal output	MWt
879.0	Total salt HTF mass flowrate	kg/s
28.4	Header corridor	m
100.5	Total length per SCA	m
12.2	Outer road corridors	m
69.6	Allowance E-W for power block	m
402	Length of 1 row with 4 SCAs	m
1155	E-W total width	m
857	N-S total width	m

- hot HTF in header and illustrative loops
- cold HTF in header and illustrative loops

270,320	SF aperture area	m <sup>2</sup>
496	Total SCAs	
62	Total rows	
62	Total loops	
17.4	Solar row spacing	
5.76	Mirror aperture	
4	SCAs/row	
8	SCAs/loop	
989,949	Total land area	m <sup>2</sup>
99	Total land area	hectares
245	Total land area	acres


# Optical Efficiency Backup

Optical Efficiency Comparison	Sandia LS-2 Test	SEGS VI LS-2 1999	New LS-2 Collector	Advanced Trough
Bellows Shadowing	0.974	0.971	0.974	0.974
Tracking Error & Twist	0.994	0.994	0.994	0.994
Geometric Accuracy	0.98	0.98	0.98	0.98
Mirror Reflectivity	0.935	0.935	0.935	0.95
Dust on Mirrors	0.974	0.931	0.95	0.97
Dust on HCE	0.99	0.977	0.983	0.99
Envelope Transmissivity	0.965	0.965	0.97	0.97
Absorption	0.925	0.937	0.96	0.97
Unaccounted	0.96	0.96	0.97	0.98
<b>Optical Efficiency</b>	<b>0.73</b>	<b>0.70</b>	<b>0.75</b>	<b>0.80</b>

# Final Comparison

Case ID	VP-1 No Sto	VP-1 66bar 2T	VP-1 66bar TC	Salt 450°C 2T	Salt 450°C TC	Salt 500°C 2T	Salt 500°C TC
Solar Field Size [m <sup>2</sup> ]	270,320	427,280	427,280	425,100	425,100	425,100	425,100
Investment Cost [M\$]	110,291	175,251	169,546	171,405	159,556	164,583	156,158
Thermal Storage Cost [M\$]	0	21,330	15,897	19,674	8,390	14,141	6,117
Annual O&M cost [k\$/yr]	3,583	4,088	4,088	4,282	4,282	4,282	4,282
Net Electric [GWh]	107.5	169.2	169.1	183.9	182.9	185.7	184.4
Mean Solar to electric efficiency	14.64%	14.58%	14.57%	15.92%	15.84%	16.08%	15.97%
<b>LEC [USD/MWh]</b>	<b>139.7</b>	<b>131.5</b>	<b>128.1</b>	<b>119.9</b>	<b>113.9</b>	<b>115.1</b>	<b>111.0</b>
LEC Reduction	-	5.9%	8.3%	14.2%	18.5%	17.6%	20.6%
Thermal Storage Cost \$/kWh el	0.0	64.6	48.2	59.6	25.4	42.9	18.5
Thermal Storage Cost \$/kWh th	0.0	23.7	17.7	23.6	10.1	17.4	7.5

# LEC Gains from Use of Calcium Nitrate Salt as HTF



# Concept Overview

- Study concluded that no overriding barriers prevent its adoption at 450°C. R&D is needed, particularly to reach 500°C operation.
- Feasible solutions have been put forward for system charging, freeze protection, recovery from freezing, and routine maintenance tasks. Selective surface and ball joints present greater challenges.
- There is no compelling economic advantage to using molten salt in a trough solar field for a system without thermal storage
- There appears to be significant economic advantages for a molten salt HTF with storage. Preliminary estimates on reductions in LEC from the reference VP-1 case (w/o storage) are significant.

# Engineering Issues


# Issues addressed

- Routine Freeze Protection
- Solar Field Preheat Methods
- Collector Loop Impedance Heating
- Materials Considerations

# Freeze Protection Methods

- Heat Collection Element
  - Cold salt circulation in routine overnight operation
  - Impedance heating for maintenance outage
  - Resistance heating cable internal to the HCE
  - Drain loop to service truck for loop piping maintenance
- HTF Header Piping
  - Cold salt circulation in routine overnight operation
  - Electric heat tracing for maintenance outage

# Overnight Cooling



# HCE Heating

- Internal resistance heating
  - Considered possible but cumbersome
- Impedance heating
  - Circumferentially uniform
  - Higher power densities possible
  - Electric system requirements high

# Collector Loop Maintenance

- Drain hot HTF into maintenance truck under slight vacuum
- Perform maintenance, e.g., HCE replacement
- Heat loop with impedance heating, and pump salt mixture into loop

# Normal Maintenance & Operation

- Within the solar field, O&M practices will change for HTF system and flow loop only, requiring different procedures for:
  - **HCE replacement, requiring taking loops out of service**
  - **Maintenance of valves, interconnections, and other fittings**
  - **Heat trace systems**
  - **Major equipment: Pumps; steam generator; TES**
  - **Instrumentation to monitor salt temperatures and heat trace system operation**
- Conservative but preliminary cost adders included in O&M budget

# Materials Considerations

Peak fluid temperature,	Basic material	ASTM <sup>a</sup> Designation				
		Pipe	Fittings	Valves	Tubes <sup>b</sup>	Plate <sup>c</sup>
325°C	Carbon steel	A 106, Grade B	A 234, Grade WPA	A 216, Grade WCB	A 192	A 516, Grade 70
450°C	Ferritic steel	A 335, Grade P22	A 234, Grade WP22	A 217, Grade WP22	A 213, Grade T22	A 387, Grade 22
500°C	Ferritic steel	A 335, Grade P91	A 234, Grade WP91	A 217, Grade WP91	A 213, Grade T91	A 387, Grade 91

Notes: a) American Society for Testing and Materials; b) For steam generator heat exchangers;  
c) For thermal storage tanks and heat exchanger shells

# Lower solar field HTF Velocities with Molten Salt

due to higher temperature rise and salt properties

